

NFRC U Factor, SHGC, VT & Condensation Report Values
- Easifold 3000 Bi-fold Door Series

Report number:	D3550.02-116-45
Rendered to:	Origin USA
Series/Model:	Easifold 3000 Bi-fold Door
Simulator:	Intertek ATI
Original report date:	03/03/14
Revised report date:	07/28/14
Frame and Sash Material:	Aluminum w/ Thermal Breaks – All Members
Specimen Size:	1920mm x 2090mm
Standards Tested:	NFRC 100-2014 NFRC 200-2014 NFRC 500-2014
Spacer Type:	Cardinal XL Edge Spacer
Best Performing U-Factor:	0.28
Best Performing SHGC:	0.14
Visible Transmittance Range:	0.52 – 0.14
Condensation Resistance Factor (CRF):	47
NFRC Inspection Agency:	

